



## Edina Emerald Energy Program (EEEP) Eligible Improvements

<u>Building Type</u>	<u>Improvement Category</u>	<u>Measure Name</u>	<u>Requirement Spec</u>	<u>Unit Measured In</u>	<u>Unit Meas Saved Or Gen</u>
All	Energy Efficiency	Attic Fan - Solar	no A/C power required	Each	Therms
All	Energy Efficiency	Core Plumbing System	Energy Star	Each	Gallons
All	Energy Efficiency	Doors, Glass	U 0.40 or less, SHGC 0.40 or less	Each	Therms
All	Energy Efficiency	Doors, Solid, Insulating	Energy Star	Each	Therms
All	Energy Efficiency	Duct Sealing	CF6R Form Required	Lin Ft	Therms
All	Energy Efficiency	Electronic Air Cleaner/Filter	(i.) Electronic Air Cleaner /Filter, high efficiency for use with HVAC systems – Whole Building (ii.) Input Power: 24Volts AC (iii.) Output Power: 24KV DC Nominal (iv.) Rated Static Pressure: 0.25" initial @ 500FPM (v.) Minimum Depth Thickness: 2.0" Nominal (vi.) Recommended media changes per year: 1-2 per year (vii.) Ozone production: 0 PPB detectable	Each	Therms
All	Energy Efficiency	Geothermal Well Drilling	Custom	Each	Therms
All	Energy Efficiency	HVAC Air Conditioning - Split System Unit	14 SEER or 12 EER	Each	Therms
All	Energy Efficiency	HVAC Heat Pumps - Geothermal Exchange Closed Loop	≥ 15.5 EER	Each	Therms
All	Energy Efficiency	HVAC Heat Pumps - Geothermal Exchange Open Loop	≥ 17.8 EER	Each	Therms
All	Energy Efficiency	HVAC, Evaporative Coolers	Separate duct system, max 5 g/ton-hour cooling	Each	Therms
All	Energy Efficiency	Insulation, Hot Water Pipes	R4	Lin Ft	Gallons
All	Energy Efficiency	Insulation, Reflective or Radiant Barriers	Energy Star	Sq Ft	Therms
All	Energy Efficiency	Insulation, Sub-floor	R19 minimum	Sq Ft	Therms
All	Energy Efficiency	Lighting Control Systems with Occupancy Sensors	Custom	Each	kWh
All	Energy Efficiency	Lighting, High Efficiency, Hard-Wired Fixtures	Energy Star, UL Listed, Title 24 Compliant	Each	kWh
All	Energy Efficiency	Pool Equipment, Pool Circulating Pumps	variable flow and/or multi-speed with controllers	Each	kWh
All	Energy Efficiency	Sealing, Whole Building	Energy Star	Sq Ft	Therms
All	Energy Efficiency	Skylights	U value 0.60 or less, SHGC 0.40 or less	Each	kWh
All	Energy Efficiency	Solar Thermal Systems for Hot Water	Rated by SRCC	Sq Ft	Therms
All	Energy Efficiency	Solar Thermal Systems for Pool Heating-Evacuated Tubes	Rated by SRCC	Sq Ft	Therms
All	Energy Efficiency	Solar Thermal Systems for Pool Heating-Panels	Rated by SRCC	Sq Ft	Therms
All	Energy Efficiency	Solar Tubes	Each	Each	kWh
All	Energy Efficiency	Water Heater, Natural Gas	≥ 0.67 EF and Energy Star	Each	Therms



## Edina Emerald Energy Program (EEEP) Eligible Improvements

All	Energy Efficiency	Storage				
All	Energy Efficiency	Water Heater, Tankless	≥ 0.82 EF and Energy Star	Each	Therms	
All	Energy Efficiency	Weather-stripping	Energy Star	Lin Ft	Therms	
All	Energy Efficiency	Window Filming	NFRC glazing ratings	Sq Ft	Therms	
All	Energy Efficiency	Windows	U 0.40 or less, SHGC 0.40 or less	Each	Therms	
	Generation	Co-generation System		Each		kWh